

Page 1 of 3

Certificate No: LR2024948TA-01 Issue Date: 21/12/2020 Expiry Date: 10/12/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer Electro Adda spa

Address Via Nazionale 8, Beverate Di Brivio Lc, 23883, Italy

Type Electric Motors

Description Three phase asynchronous motors IE2 (High), IE3 (Premium), IE4 (Super-

premium) efficiency classes

Trade Name C2A, C3A, C4 (horizontal shaft line) and FC2A, FC3A, FC4 (vertical shaft line)

Application Marine, Offshore and Industrial use.

Specified Standard IEC 60034-1:2017

IEC 60034-2-1:2014 IEC 60034-6:1991 IEC 60034-30-1:2014

Lloyd's Register Rules and Regulation for the Classification of Ships (2020), Part

6, Chapter 2, Section 9

Lloyd's Register Rules and Regulation for the Classification of Naval Ships

(2020), Volume 2, Part 9

Maurizio Crucil

TTSO Senior Specialist to Lloyd's Register

A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 3

Certificate No: LR2024948TA-01 Issue Date: 21/12/2020 Expiry Date: 10/12/2025

Type Approval Certificate

Ratings Rated Power [kW]: $0.75 \div 200$

Rated Voltage [V]: $220 \div 690$

50 / 60 or variable up to 200kW Rated Frequency [Hz]:

Efficiency Classes: IE2 (C2A, FC2A)

IE3 (C3A, FC3A) IE4 (C4, FC4)

Shaft height [mm]: $80 \div 315$ Poles Number: 2-4-6-8

Insulation Class:

Degree of Protection: IP55 or IP56

Duty Type:

Frame: Aluminium or Cast Iron fabricated steel

IC411 and IC416 Cooling Codes:

Reference Ambient Temperature: 45°C

Other Conditions

- Temperature Rise for Lloyd's Register application have to be within insulation class F limits, as per Lloyd's Register Rules and Regulation for the Classification of Ships, 2015 - Part 6, Chapter 2, Section 9.
- Temperature Rise for Power Frequency applications satisfies class B limits, except for C2A 225 MT 2 poles, within class F limit.
- Motors suitable for Inverted-Fed application, without any needs of power de-rating. Temperature Rise within class F limits.
- Motors rated 100 kW and above intended for Lloyd's Register application have to satisfy the additional requirements as specified in the LR Rules and Regulation for the Classification of Ships, Part 6, Chapter 2.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 3 of 3

Certificate No: LR2024948TA-01 Issue Date: 21/12/2020 Expiry Date: 10/12/2025

Type Approval Certificate

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: The present certificate is intended as renewal and amendment of Certificate 16/00038 (E1).

The Design Appraisal Document LR2024948DA-01 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.